

M9[®] and M11[®] Vent Valve Repair Kit

002-11013-00 115 VAC
002-11013-01 230 VAC

Applies to Models:

M9 (-050/-053)

M11 (-050/-051/-053)

Special Tools:

T25 Torx Screw Driver



WARNING


To prevent risk of shock always disconnect power before removing covers or performing any service procedure.



WARNING


Allow to cool to ambient / room temperature prior to removing cover. Release pressure by pulling ring of pressure relief valve if necessary.

Step 1: Disconnect power.



Step 2: Drain water from reservoir.


- A) Disconnect the drain tube from the clips.
- B) Bend tube downward and drain reservoir into a suitable container.



ArtHalf


Step 3: Remove right side cover.

- A) Remove top two right side screws and loosen right rear bottom screw.
- B) Pull corner tab out of corner slot and rotate top of side cover down to free bottom tabs from base of sterilizer.



Step 4: Remove vent valve assembly.

- A) Disconnect copper tube from top of vent valve using a 1/2" wrench.
- B) Remove adapter fitting using a 5/8" wrench. Remove 3/4" nut with wrench.
- C) Remove spade connectors from coil and remove coil.
- D) Using a spanner wrench remove the valve stem, spring and plunger from manifold.



Step 5: Install new vent valve assembly.

- A) Using a spanner wrench install new valve stem, spring and plunger into manifold.
- B) Install coil onto valve stem and secure with 3/4" nut and attach wiring spade connectors to coil.
- C) Install adapter fitting into top of valve stem using a 5/8" wrench and connect copper tube from top of vent valve using a 1/2" wrench.


Step 6: Install right side cover.

- A) Insert bottom tabs of right side cover into base of sterilizer.
- B) Rotate top of side cover up into position and snap corner tab into corner slot.
- C) Install top two right side screws and tighten right rear bottom screw.




WARNING

For effective grounding make sure star washer is located between screw head and tab of side cover when tightening right rear bottom screw.



Step 7: Add water to reservoir and run a test cycle.

- A) Pour distilled water into fill opening until water level reaches top of the fill level.
- B) Run a test cycle and check for leaks.



Equipment Alert

Use distilled water or water that meets referenced water purity specifications in the User Guide. Failure to comply may result in sterilizer malfunction and/or premature failure due to excessive corrosion.

Step 8: Qualification Testing.

A) *Qualification Testing Cycles should be run after this repair is completed. (Refer to the user guide for details.)*

If the sterilizer is connected to Smart View, a Request Qualification Testing should be setup on the sterilizer display following the below steps:

- *Press the Menu Button .*
- *Select Settings.*
- *Select Service.*
- *Select Troubleshooting.*
- *Select Qualification Testing.*
- *Select Request Qualification Testing.*
- *Select Yes, Request Qualification Testing.*

Note: Once qualification testing has been requested, this page will track testing status. The user interface will ask the user if the cycle they are attempting to run is a qualification cycle until the three (3) qualification cycles are completed.